



Slemon Park PFAS Testing May 2023

Report Number: N/A
Client: N/A
Address.: N/A
City: N/A
Telephone: N/A
Contact: N/A
Date Reported: N/A

May 29, 2023 was conducted by PEI Dept. of Environment

Analyte	Units	MRL	Lab ID	Well#1 2023-05-29
			Sample ID Sample Date	
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	ng/L	1.0		<1.0
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)	ng/L	2.0		<2.0
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2FTS)	ng/L	2.0		<2.0
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)	ng/L	2.0		<2.0
4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	ng/L	1.0		<1.0
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	ng/L	1.0		<1.0
Hexafluoropropylene oxide dimer acid (HFPO-DA)	ng/L	1.0		<1.0
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	ng/L	1.0		<1.0
Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	ng/L	1.0		<1.0
Perfluoro-3-methoxypropanoic acid (PFMPA)	ng/L	1.0		<1.0
Perfluoro-4-methoxybutanoic acid (PFMBA)	ng/L	1.0		<1.0
Perfluorobutanesulfonic acid (PFBS)	ng/L	1.0		2.1
Perfluorobutanoic acid (PFBA)	ng/L	3.0		2.7
Perfluorodecanoic acid (PFDA)	ng/L	1.0		<1.0
Perfluorododecanoic acid (PFDoA)	ng/L	1.0		<1.0
Perfluoroheptanesulfonic acid (PFHpS)	ng/L	1.0		<1.0
Perfluoroheptanoic acid (PFHpA)	ng/L	1.0		2.9
Perfluorohexanesulfonic acid (PFHxS)	ng/L	1.0		19.3
Perfluorohexanoic acid (PFHxA)	ng/L	1.0		4.4
Perfluorononanoic acid (PFNA)	ng/L	1.0		<1.0
Perfluorooctanesulfonic acid (PFOS)	ng/L	1.0		6.5
Perfluorooctanoic acid (PFOA)	ng/L	1.0		4.7
Perfluoropentanesulfonic acid (PFPeS)	ng/L	1.0		<1.0
Perfluoropentanoic acid (PFPeA)	ng/L	1.0		5.7
Perfluoroundecanoic acid (PFUnA)	ng/L	1.0		<1.0
PFAS HC Sum (25)	ng/L	3		48.3

Please refer to the accompanying digitally signed PDF version of the report for official results.