



**PEI Analytical Laboratories
Water Quality Test Report**

23 Innovation Way, Charlottetown, PE C1E 0B7



Client Name: Slemon Park Corporation Property Management

Sampler: Brad Paugh, 439-0210

Sample Location: 800 Aerospace Bl, Slemon Park

Sample Point: Cold Water Tap

Water Type: Drinking Water

Sample Number: P230125029

Date Sampled: 25-Jan-2023

Received Date: 25-Jan-2023

Reported Date: 21-Feb-2023

Water Microbiology Results

<u>Method ID</u>	<u>Parameter</u>	<u>Results</u>	<u>Units</u>	<u>Detection Limits</u>	<u>Date of Analysis³</u>
WML_01M*	Total Coliform*	0	cfu/100 ml	0	26-Jan-2023
WML_01M*	E. coli*	0	cfu/100 ml	0	26-Jan-2023
WML_01M*	Background Growth*	0	cfu/ 100 ml	0	26-Jan-2023
WML_01M*	Temperature upon receipt*	10.0	°C	0	26-Jan-2023

Water Chemistry Results

<u>Method ID</u>	<u>Parameter</u>	<u>Results</u>	<u>Units</u>	<u>Detection Limits</u>	<u>Date of Analysis³</u>
WCL_04M*	pH for Water*	7.7			31-Jan-2023
WCL_01M*	Alkalinity*	150	mg of CaCO ₃ /L	8.0000	07-Feb-2023
WCL_01M*	Chloride*	188.2	mg/L	1.0000	15-Feb-2023
WCL_09M*	Barium, dissolved*	0.3616	mg/L	0.0005	30-Jan-2023
WCL_07M*	Calcium, dissolved*	122.30	mg/L	0.2000	02-Feb-2023
WCL_07M*	Potassium, dissolved*	1.14	mg/L	0.1000	02-Feb-2023
WCL_09M*	Copper, dissolved*	0.0120	mg/L	0.0020	30-Jan-2023
WCL_09M*	Iron, dissolved*	<0.0020	mg/L	0.0020	02-Feb-2023
WCL_07M*	Magnesium, dissolved*	2.87	mg/L	0.1000	02-Feb-2023
WCL_09M*	Manganese, dissolved*	<0.0005	mg/L	0.0005	30-Jan-2023
WCL_07M*	Phosphorus, dissolved*	<0.02	mg/L	0.0200	02-Feb-2023
WCL_07M*	Sodium, dissolved*	74.86	mg/L	0.2000	02-Feb-2023
WCL_07M*	Sulfate, calc from S diss*	20.09	mg/L	0.2000	02-Feb-2023
WCL_09M*	Lead, dissolved*	<0.0001	mg/L	0.0001	30-Jan-2023
WCL_09M*	Zinc, dissolved*	0.0030	mg/L	0.0020	02-Feb-2023
WCL_07M*	Hardness*	317.2	mg/L as CaCO ₃	0.0000	07-Feb-2023
WCL_09M*	Arsenic, dissolved*	0.0002	mg/L	0.0001	30-Jan-2023
WCL_01M*	Nitrate-N + Nitrite-N*	3.3	mg/L	0.2000	07-Feb-2023
WCL_09M*	Selenium, dissolved*	<0.0002	mg/L	0.0002	30-Jan-2023
WCL_09M*	Uranium, dissolved*	0.0005	mg/L	0.0001	30-Jan-2023

Lab Results Approved By: Lori Brine - Laboratory Manager

Date: 17-Feb-2023

Legend:

MPN = Most Probable Number

cfu/100 mls = colony forming units per 100 millilitres

* = method accredited by Standards Council of Canada

Ammonia is equivalent to (Ammonia + Ammonium)-N

³Dates of Analysis refers to the date of performance of lab activities .

mg/L = milligrams per litre

nd = not detected; na = not analysed

< = less than

²=Estimated

Results in this report relate only to the actual submitted and tested sample. This report may not be reproduced except in full, without written approval from the laboratory. Please take a moment to complete our customer satisfaction survey at <https://peial.questionpro.ca>



Tel 902 368 5044
Toll free 1 866 368 5044
Fax 902 368 5830
www.gov.pe.ca/enveng

Department of Environment, Energy and Climate Action

PO Box 2000
Charlottetown
Prince Edward Island

Sample Code: P230125029

Slemon Park Corporation Property Management
PO Box 90, 30 Aerospace Blvd
Slemon Park, PE
Canada
C0B 2A0

Dear Client:

Please find on the Water Quality Test Report the laboratory test results for sample # P230125029 sampled on Jan 25, 2023

Please note that the sample submission form was accompanied by the following information:

Well Location / Facility Name: Slemon Park Corporation, Slemon Park Water Distribution System

Sample Point: Cold Water Tap

Chlorine Residual: 0.54

Notes: In service, on account.

The results of this analysis indicate:

The results and interpretation contained in this report relate only to the parameters tested.

For your information and interpretation.

Approved By:

End of Report

Scott Gamble

Results in this report relate only to the actual submitted and tested sample. This report may not be reproduced except in full, without written approval from the laboratory. Please take a moment to complete our customer satisfaction survey at <https://peial.questionpro.ca>